




MAS2-Regler Version 7	Hand / 0 / Auto - Türschalter	Schwimmerkontakt	Kaltleitereingang	Laufsignal	Aktivlüfter	Heizung
2 Pumpen Anlage mit:						



Steuerklemmen:	5VDC	24VDC	Steuerklemmen:	24VDC	230VAC	Steuerklemmen:	24VDC	230VAC
			81 + 24VDC	X				
			81 + 24VDC	X				
			82 - 0 VDC	X				
			83 - Sensorsignal 10V P1	X				
			84 - Sensorsignal 10V P2	X				
7 extern Start / Stopp		X	1 Relais p.f. Mitte P1		X			
8 extern Hand / Reset		X	2 Relais p.f. Schliesser P1		X			
27 extern Start / Stopp		X	3 Relais p.f. Öffner P1		X			
28 extern Hand / Reset		X	21 Relais p.f. Mitte P2		X			
			22 Relais p.f. Schliesser P2		X			
			23 Relais p.f. Öffner P2		X			

	Harzer Strasse 10 49124 Georgsmarienhütte Tel.: +49(0)5401-8388-0	Gez.: S. Mausch	Datum: 10.03.2010
		Änd.:	Erstellt: U. Molitor